



CB TEST CERTIFICATE

Ref. Certificate No.

NL-22139

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Residual current operated circuit-breakers with overcurrent protection		
Applicant:	ETI Elektroelement d.d.	Obrezija 5, SI-1411 Izlake	Slovenia
Manufacturer:	ETI Elektroelement d.d.	Obrezija 5, SI-1411 Izlake	Slovenia
Factory:	ETI Elektroelement d.d.	Obrezija 5, SI-1411 Izlake	Slovenia
nb: Additional factory information on page 2			
Rating and principal characteristics:	In = 6, 10, 13, 16, 20, 25 A; I Δ n = 10, 30, 100 mA; Ue = 230 / 240 Vac; 1P+N; type A and AC; without time delay; characteristic B and C, Icn = 6 kA; Ics = 6 kA; I Δ m = 1,5 kA; safety distance "a" 40 mm; Uimp = 4 kV; 50 / 60 Hz;		
Trade mark (if any):	ETI		
Type of Manufacturer's Testing Laboratories used:	WMT		
Model/Type reference:	KZS-1M		
Additional information:	Energy limiting class 3 according to EN 61009-1		
Sample of product tested to be in conformity with IEC:	61009-1(ed.3) 61009-2-2(ed.1)		
Test Report Ref. No:	2143735.50		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: H.L. Schendstok

Date of issue: 2011-11-25



DEKRA Certification is
former KEMA Quality



IEC SYSTEM FOR CONFORMITY TESTING
TO STANDARDS FOR SAFETY OF
ELECTRICAL EQUIPMENT (IECEE) CB
SCHEME



Ref. Certificate No.

NL-22139

ETI-Polam Sp. Z o.o.
Ul. Jana Pawla II 18,
06-100 Pultusk
Poland

Additional information (if necessary)

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: H.L. Schendstok

Date of issue: 2011-11-25



DEKRA Certification is
former KEMA Quality